

Discharge Limitations

<u>Parameter</u>	<u>Limitation</u>	
Cadmium	0.04 mg/l	40 ug/l
Chromium	1.71 mg/l	1,710 ug/l
Copper	1 mg/l	1,000 ug/l
Lead	0.1 mg/l	100 ug/l
Silver	0.24 mg/l	240 ug/l
Zinc	1.2 mg/l	1,200 ug/l
Nickel	2 mg/l	2,000 ug/l
Cyanide	0.65 mg/l	650 ug/l
pH	5.5 to 10.5 standard units	
Mercury	0.06 mg/l	60 ug/l
Arsenic	0.12 mg/l	120 ug/l
Total Toxic Organics (TTO)	2.13 mg/l	2.130 mg/l
BOD	300 mg/l	300 mg/l
TSS	300 mg/l	300 mg/l
Total Petroleum Hydrocarbons (TPH)	2 mg/l	2 mg/l
Gold	3 mg/l	3 mg/l
Iron	15 mg/l	15mg/l
Tin	0 mg/l	0 mg/l
Metals not mentioned	2 mg/l	2 mg/l
Sulfides (S)	100 mg/l	100 mg/l
Sulfates (SO ₄)	500 mg/l	500 mg/l
Fluoride	5 mg/l	5 mg/l
Mercury Chloride (as Mercury, Hg)	0.5 mg/l	500 ug/l
Phenols (not to exceed)	1 mg/l	1 mg/l
Solvents	0 mg/l	0 mg/l
Total Oil & Grease	100 mg/l	100 mg/l

ug/l = micrograms per liter (parts per billion)

mg/l = milligrams per liter (parts per million)