



**NEWPORT FIRE DEPARTMENT**  
**OFFICE OF FIRE PREVENTION**  
21 West Marlborough Street  
Newport, RI 02840  
Phone: (401) 845-5920  
Fax: (401) 845-5940



## **Congregate Family Living Facility** **Smoke and Carbon Monoxide Alarm Requirements**

### **ALL DEVICES ARE REQUIRED TO BE LESS THAN 10 YEARS DATE OF MANUFACTURE**

- (1) Smoke Alarms shall be installed inside each bedroom, outside sleeping areas within 21 ft of bedroom door and on each level of the dwelling unit(s) (including basements)
- (2) Smoke Alarms shall be hard-wired with battery backup.  
*(May use battery operated and wireless interconnected devices listed at bottom of page 2)*
- (3) Smoke Alarms shall be required to be interconnected.
- (4) Carbon Monoxide Alarms or Detectors shall be installed within 21 ft of bedroom door outside each sleeping area and one on every level.
- (5) Carbon Monoxide Alarms or Detectors shall be hard-wired with battery backup.
- (6) Carbon Monoxide Alarms or Detectors shall be required to be interconnected.
- (7) When floor area of a given level of a dwelling unit exceeds 1000 square feet, smoke alarms shall be installed for every 30 ft travel distance or 1 smoke alarm for every 500 square feet of floor area.

**\*\*\*\* See pages 2 & 3 for specific mounting locations \*\*\***

#### **Wireless Smoke and Carbon Monoxide Alarms (NFPA 72:29.9.1)**

- 1) 10 Year Sealed Battery
- 2) Listed and Approved Device
- 3) Visible "power on" indicator is provided (may be intermittent)

#### **Non-Supervised Wireless Interconnected Devices (NFPA 72: 29.10.8.2)**

- 1) Shall be capable of reliably communicating at a distance of 100ft indoors
- 2) Listed and Approved Device

#### **Maximum # of Devices (NFPA 72: 29.11.2.1)**

- 1) Maximum number of single station unsupervised interconnected devices is **18** of which a maximum of **12** can be smoke alarms.
- 2) Maximum number of supervised interconnected devices is **64** of which a maximum of **42** can be smoke alarms.

***The above smoke and carbon monoxide alarms may be installed as follows:***

***(1) Where the above provisions require both smoke alarms and carbon monoxide alarms or detectors, combination devices shall be permitted and deemed acceptable.***

***(2) Where smoke alarms are required, household fire alarm systems, in accordance with NFPA 72 (2019 Edition), shall be permitted and deemed to be acceptable***



**NEWPORT FIRE DEPARTMENT**  
**OFFICE OF FIRE PREVENTION**  
21 West Marlborough Street  
Newport, RI 02840  
Phone: (401) 845-5920  
Fax: (401) 845-5940



## Specific Locations

### Kitchens and Cooking Appliances

- 1) Smoke alarms and detectors shall not be installed within a **10ft** radial distance along a horizontal flow path from stationary or fixed cooking appliance unless listed for installation in close proximity.
- 2) All detectors and alarms installed between **10ft** and **20ft** of horizontal flow path from stationary or fixed cooking appliance shall be equipped with an alarm-silencing means or use photoelectric detection.
- 3) Effective January 1, 2022, smoke alarms and smoke detectors installed between **6ft** (1.8 m) and **20ft** (6.1 m) along a horizontal flow path from a stationary or fixed cooking appliance **shall be listed** for resistance to common nuisance sources from cooking.

### Bathrooms

- 1) Smoke alarms and detectors shall not be installed within a **36 in.** horizontal path from a door to a bathroom containing a shower or tub **unless** listed for installation in close proximity to such locations.

### Forced Air

- 1) Smoke alarms and smoke detectors shall not be installed within a **36 in.** (910 mm) horizontal path from the supply registers of a forced air heating or cooling system and shall be installed outside of the direct airflow from those registers.

### Ceiling Fans

- 1) Smoke alarms and smoke detectors shall not be installed within a **36 in.** (910 mm) horizontal path from the tip of the blade of a ceiling-suspended (paddle) fan **unless** the room configuration restricts meeting this requirement.

### Stairways

- 1) Where stairs lead to other occupiable levels, a smoke alarm or smoke detector shall be located so that smoke rising in the stairway cannot be prevented from reaching the smoke alarm or smoke detector by an intervening door or obstruction.
- 2) For stairways leading up from a basement, smoke alarms or smoke detectors shall be located on the basement ceiling **near** the entry to the stairs.

### Environment Code Considerations

- 1) Smoke alarms and smoke detectors shall not be located where ambient conditions, including humidity and temperature, are outside the limits specified by the manufacturer's published instructions.
- 2) Smoke alarms and smoke detectors shall not be located within unfinished attics or garages or in other spaces where temperatures can fall below 40 F (4.4 C) or exceed 100 F (38 C).

### Walls

- 1) Smoke alarms or smoke detectors mounted on walls shall be located **not farther than 12 in.** from the adjoining ceiling surface (measured from the top of the detector).

### Ceilings *(For beam and joists ceilings please contact fire prevention office for assistance)*

- 1) For tray-shaped ceilings (coffered ceilings), smoke alarms and smoke detectors shall be installed on the highest portion of the ceiling or on the sloped portion of the ceiling within **12 in.** (300 mm) vertically down from the highest point.
- 2) **FOR PEAKED OR SLOPED CEILINGS PLEASE SEE PAGE 4 ENTITLED SPECIFIC CEILING LOCATION REQUIREMENTS**

### Other


- 1) Where a sleeping area is separated from the adjacent living areas by multiple doors, a smoke alarm shall be installed in the area between the door and the sleeping rooms, and additional alarms shall be installed on the living area side of the door (NFPA 72:29.8.1.2)



**SMOKE ALARM & SMOKE DETECTOR  
CEILING  
INSTALLATION REQUIREMENTS**

**Peaked Ceilings**

- 1) Smoke alarms or smoke detectors mounted on a peaked ceiling shall be located within 36 in. horizontally of the peak, but not closer than 4 in



**Sloped Ceilings**

- 1) Smoke alarms or smoke detectors mounted on a sloped ceiling having a rise greater than 1 ft in 8 ft shall be located within 36 in. of the high side of the ceiling, but not closer than 4 in. from the adjoining wall surface.

